

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Galaxy Public School
Galaxy Enclave, Sector:-E-Extension
Sainik Colony, Jammu

No: JDJF&ES/FPI/7507

Dated: 22-11-2022

Sub: Fire Safety Certificate.

Ref: Your online application submission dated: 20.07.2022.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed two number Hose Reel Hoses and First Aid Fire Extinguisher in their school premises. Besides this, one underground water storage tank of 35 KL capacity is also available. The school is about 07 Km away from Fire and Emergency Station Gangyal and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such the management can proceed ahead for operation subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building.
4. All class rooms and examination halls having seating capacity for more than 45 students needs to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance issued will be treated automatically withdrawn/cancelled.
7. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
8. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
9. At present school is triple storey. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
10. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
11. The department can make a surprise visit to your institute at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
12. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school building (i.e. existing as well as proposed). However, before granting permission/recognition/ extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010, issued by Education Department with regard to Physical facilities.

Yours faithfully

Joint Director

Fire & Emergency Services
Jammu Range, Jammu

[Signature]
Principal
Galaxy Public School
Jammu

[Signature]
Principal
Galaxy Public School
Jammu
[Signature]
Manager
Galaxy Public School
Sainik Colony, Jammu

22/11/2022